



Red River Authority of Texas

TODD W. BOYKIN, President, Amarillo
MICHAEL R. SANDEFUR, Secretary-Treasurer, Texarkana
STEPHEN A. THORNHILL, Assistant Secretary, Denison
MARY LOU BRADLEY, Memphis
JERRY BOB DANIEL, Truscott
JERRY DAN DAVIS, Wellington
GEORGE WILSON SCALING, II, Henrietta
ZACKARY K. SMITH, Canyon
JOE L. WARD, Telephone

RANDALL W. WHITEMAN, General Manager
FABIAN A. HEANEY, Assistant General Manager
DANNA P. BALES, Executive Assistant
LANA HEFTON, Controller

January 28, 2020

**NOTICE OF VIOLATION
TRIGGERED SOURCE MONITORING AND REPORTING VIOLATION:
GROUNDWATER RULE
RRA – Farmers Valley Water System, PWS ID # 2440007**

The **RRA – Farmers Valley Water System, PWS ID # 2440007** failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the groundwater system during **August 2019**. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active groundwater well source. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

What should I do?

There is nothing you need to do at this time.

What is being done?

The Red River Authority of Texas has taken the following corrective action. Additional bacteriological samples have been taken to verify the water is safe to drink.

If you have questions regarding this matter, you may contact Mr. Ron Mullins, Utility Supervisor, or Mr. Fabian Heaney, Assistant General Manager, at (940) 723-8697.

Sincerely,

RED RIVER AUTHORITY OF TEXAS

A handwritten signature in black ink that reads "Ronald A. Mullins".

Ron Mullins
Utility Supervisor

RAM:ram

P.O. Box 240 · Wichita Falls, Texas 76307-0240

3000 Hammon Road · Wichita Falls, Texas 76310-7500

Telephone: (940) 723-8697

E-Mail: info@rra.texas.gov

Fax: (940) 723-8531